


TECHNICAL DATA

Fluke 301B











Key features

- The body weighs only 132g and is 16mm thick, which is light and portable and can be fitted into a pocket
- The slim and thin jaw of only 10mm can easily clamp onto tightly packed wires
- 600A AC range, 0.01A high resolution
- Tests voltage, resistance and continuity
- Tests current frequency and voltage frequency
- Tests capacitance and diodes
- Backlight

Product overview: Fluke 301B

Fluke 301B

The Fluke 301B Clamp Meter has a lightweight and compact body, which allows you to carry it around in your pocket. The slim and thin jaw can easily clamp onto tightly packed wires. The Fluke 301B tests current, voltage, resistance, continuity, frequency (voltage and current), capacitance, and diode, etc.. You can handle more testing needs with it.

Specifications: Fluke 301B

Specifications

Accuracy is specified for 1 year after calibration, with operating temperatures from 18 $^{\circ}$ C to 28 $^{\circ}$ C and relative humidity from 0 $^{\circ}$ 6 to 75 $^{\circ}$ 6. Accuracy specifications take the form of:

 \pm ([% of Reading] + [Number of Least Significant Digits]).

Models		301A/301A+		301B		301C		
AC Current (45 to 400 Hz)	Range	40.00 A	400.0 A	60.00 A	600.0 A	60.00 A	600.0 A	1000 A
	Resolution	0.01 A	0.1 A	0.01 A	0.1 A	0.01 A	0.1 A	1 A
	Accuracy	2 % + 10	2 % + 5	2 % + 10	2 % + 5	2 % + 10	2 % + 5	2 % + 5
AC Voltage (45 to 400 Hz)	Range	600.0 V		600.0 V		600.0 V		
	Resolution	0.1 V		0.1 V		0.1V		
	Accuracy	1.5% + 5		1.5% + 5		1.5% + 5		
DC Voltage	Range	600.0 V		600.0 V		600.0 V		
	Resolution	0.1 V		0.1 V		0.1 V		
	Accuracy	1% + 5		1% + 5		1% + 5		
Resistance	Range	600.0 Ω 6.000 kΩ 60.00 kΩ		600.0 Ω 6.000 kΩ 60.00 kΩ		600.0 Ω 6.000 kΩ 60.00 kΩ		
	Accuracy	1% + 5		1% + 5		1% + 5		



Voltage Frequency	Range	9.999 Hz 99.99 Hz 999.9 Hz 9.999 kHz 99.99 kHz			9.999 Hz 99.99 Hz 999.9 Hz 9.999 kHz 99.99 kHz		9.999 Hz 99.99 Hz 999.9 Hz 9.999 kHz 99.99 kHz		
	Accuracy	0.1% + 3			0.1% + 3		0.1% + 3		
Current Frequency	Range	45.0 to 40	0.0 H	Z	45.0 to 400.0 Hz		45.0 to 400.0 Hz		
	Accuracy	0.1% + 3			0.1% + 3		0.1% + 3		
Capacitance	Range	9.999 uF	99.99 uF 999.9 uF		9.999 uF	99.99 uF 999.9 uF	9.999 uF	99.99 uF 999.9 uF	
	Accuracy	2 % + 5	5% +	5	2 % + 5	5% + 5	2 % + 5	5% + 5	
Diada	Range	3.000 V			3.000 V		3.000 V		
Diode	Accuracy	10%		10%		10%			
T-rms Value		-		-					
Continuity									
Hold									
Backlight		-							
Safety rating		CAT III 300V		CAT III 300V		CAT III 300V			
Weight		132 g		132 g		132 g			
Size		190 mm x 52 mm x 16 mm		190 mm x 52 mm x 16 mm		190 mm x 52 mm x 16 mm			
Jaw Opening		34 mm		34 mm		34 mm			
Clamp Arm Size		10 mm X 10 mm		10 mm X 10 mm		10 mm X 10 mm			
Baery		(2) AAA Baeries		(2) AAA Baeries		(2) AAA Baeries			
Warranty		1 year		1 year		1 year			
General Specification	ons								
Maximum Voltage between any Terminal and Earth Ground				300 V					
Maximum Differential Voltage between V/ Ω and COM Terminals			600 V						
Display (LCD)			6000 counts, updates 3 times per second						
Baery Type			2 AAA, IEC LR03						
Baery Life			500 hours minimum						
Auto Power Off Time			20 minutes						
Temperature			Operating: -10 °C to 50 °C□						
			Storage: -30 °C to 60 °C						
Relative Humidity			Operating Humidity: Non condensing (<10°C);						



Altitude	Operating: 2000 m; Storage: 12000 m				
Temperature Coefficient	0.1 x (specified accuracy) /°C (<18 °C or>28 °C)				
Dimensions (H x W x L)	190 mm x 52 mm x 16 mm				
Weight	132 g				
Jaw Opening	34 mm				
Ingress Protection Rating	IP30				
Safety	IEC 610101, IEC61010-2-032 CAT III 300 V, Pollution Degree 2				
Electromagnetic Environment	IEC 613261: Portable				



Ordering information



Fluke 301B

Models: Fluke 301B Clamp Meter

Fluke 301B

- Fluke 301B Clamp Meter
- TL75 test lead
- (2) AAA batteries



$\textbf{Fluke}. \ \textit{Keeping your world up and running.} \\ \textbf{@}$

Fluke Corporation

PO Box 9090, Everett, WA 98206 U.S.A.

For more information call: In the U.S.A. (800) 443-5853

In Canada (800) 36-FLUKE From other countries +1 (425) 446-5500 www.fluke.com ©2025 Fluke Corporation.

Specifications subject to change without notice.

03/2025

Modification of this document is not permitted without written permission from Fluke Corporation.