

TECHNICAL DATA

Fluke 353 True RMS 2000 A Clamp Meter



Key features

- Reliably handle a wide range of high-current applications with 2000 A AC + DC true-rms, 1400 A ac, and 2000 A DC
- The large 58 mm (2.3 in) jaw capacity is suitable for large or multiple conductors
- CAT IV 600 V, CAT III 1000 V rating for added user protection
- In-rush current measurement captures 'power-on' surge current with accuracy and repeatability
- Accurately measure frequency up to 1 kHz for optimum troubleshooting
- Quickly analyze readings using the MIN, MAX, and AVG functions
- A large backlit display allows for easy visibility in low-lit areas
- Use the display hold feature to capture readings even when the display cannot be viewed
- Use the low-pass filter to smooth out noisy loads and stabilize readings

Product overview: Fluke 353 True RMS 2000 A Clamp Meter

Versatile and rugged tool for applications with high currents

Confidently take reliable readings with the True RMS, Fluke 353 digital clamp meter; the tools of choice for high current clamp-on amp meter measurement up to 2000 A. The extra-wide jaw easily clamps around large conductors, typically found in high-current applications. The extra rugged design and CAT IV 600 V, CAT III 1000 V ratings add an extra element of user protection when taking high-powered measurements.

Accurate peak measurements can be taken using the in-rush current mode, ideal for motors and inductive loads.



Specifications: Fluke 353 True RMS 2000 A Clamp Meter

Electrical Specifications				
Current measurement DC and AC 10 Hz to 100 Hz	Range	40 A / 400 A / 2000 A / 1400 AC RMS		
	Resolution	10 mA / 100 mA / 1 A		
	Accuracy	A: 1.5% rdg + 15 digits A: 1.5% rdg + 5 digits		
	Trigger level for Inrush	0.50 A / 5.0 A / 5 A		
	Trigger level for Hz filter OFF	2.50 A / 2.5 A / 8 A		
	Trigger level for Hz filter ON	0.50 A / 2.5 A / 8 A		
Crest Factor (50/60 Hz)	Range	40 A / 400 A / 2000 A / 1400 AC RMS		
	Crest Factor ¹	2 @ 33 A, 2.4 @ 27 A 2 @ 330 A, 2.4 @ 270 A 2 @ 1000 A, 2.4 @ 833 A		
Current measurement AC 100.1 Hz to 1 kHz	Range	40 A / 400 A / 2000 A; 1400 AC RMS		
	Resolution	10 mA / 100 mA / 1 A		
	Accuracy	10 A: 3.5% rdg + 15 digits 10 A: 3.5% rdg + 5 digits		
	Trigger level for Inrush	0.50 A / 5.0 A / 5 A		
	Trigger level for Hz filter OFF	2.50 A / 2.5 A / 8 A		
	Trigger level for Hz filter ON	0.50 A / 2.5 A / 8 A		
Frequency measurement	Measurement range	5.0 Hz to 1 kHz		
	Resolution	0.1 Hz (15 Hz to 399.9 Hz); 1 Hz (400 Hz to 1 kHz)		
	Accuracy – 5.0 Hz to 100 Hz	0.2% + 2 counts		
	Accuracy – 100.1 Hz to 1 kHz	0.5% + 5 counts		
	Trigger level	Refer to current and voltage tables		
1. Add 2% to error spec for CF > 2				
General Specifications				
Baeries	Six 1.5 V AA NEDA 15 A or IEC LR6			
Baery life (with typical usage, backlight off)	100 hours			
Test leads	Rated to 1000 V			
Weight	.814 kg (1.8 lb)			
Jaw size	58 mm (2.28 in)			
Dimensions (L x W x D)	300 x 98 x 52 mm (12 x 3.75 x 2 in)			
Safety rating	IEC 61010-2-032, 600 V CAT IV, 1000 V CAT III			

 Environmental Specifications

 Operating temperature
 32°F to +122°F (0°C to +50°C)

2 Fluke Corporation Fluke 353 True RMS 2000 A Clamp Meter



Storage temperature	-4°F to 140°F (-20°C to +60°C)		
Operating humidity	0 to 95% (non-condensing)		
Operating altitude	2000 m		
Storage altitude	10,000 m		
IP rating	42 (indoor use only)		
Drop test requirements	1 m		
EMI, RFI, EMC	FCC part 15, IEC/EN 61326-1:1997 class B IEC/EN 61326:1997 3V/m, performance criteria B, EN61325		
Temperature coefficients	Current	0.1% of reading per °C outside 22°C to 24°C	
	Voltage	0.1% of reading per °C outside 22°C to 24°C	



Ordering information



Fluke 353

Fluke 353 True RMS 2000 A Clamp Meter

Includes:

- 353 clamp meter
- C43 Soft carrying case
- 6 AA batteries
- User manual
- 3 year warranty



Fluke. Keeping your world up and running.®

Fluke Corporation PO Box 9090, Everett, WA 98206 U.S.A.

For more information call:

In the U.S.A. (800) 443-5853 In Canada (800) 36-FLUKE From other countries +1 (425) 446-5500 www.fluke.com ©2025 Fluke Corporation. Specifications subject to change without notice. 04/2025

Modification of this document is not permitted without written permission from Fluke Corporation.